




The University of Georgia

College of Agricultural and Environmental Sciences
Cooperative Extension



Poultry Housing Tips

Best Performing Tunnel Fans - 2015

Volume 27 Number 9

2015

When building a new house or retrofitting an older one for tunnel ventilation, fan selection is one of the most, if not the most important decision a producer has to make. A house's fans are essentially the engine of the ventilation system and as a result have a significant effect on a producer's ability to maintain the proper environmental conditions throughout the year. Furthermore, with rising electricity prices selecting the right energy efficient fan can save a producer thousands of dollars a year. As a result, when selecting fans it is crucial that a producer compares fans not just on initial cost but on fan performance and operating costs as well.

University of Illinois BESS Laboratory "Agricultural Ventilation Fans Performance and Efficiencies" test booklet is the leading source for agricultural fan performance data (an electronic version of the test booklet can be found at www.bess.uiuc.edu.) Along with a fan's air moving capacity at various static pressures BESS Laboratory provides producers information on a fan's energy efficiency rating (cfm/watt) and air flow ratio (an indicator of how well the fan holds up under high static pressures). A detailed explanation of exhaust fan performance factors can be found in the May 2006 issue of *Poultry Housing Tips*.

Table 1 lists the top performing tunnel fans (48" to 62", 230V/Single phase, 60 hz) based on the published test results produced by the BESS Laboratory through December of 2015. The fans in Table 1 have an energy efficiency rating of at least 20.8 cfm/watt @ 0.10" static pressure and have an air flow ratio of at least 0.76, thus representing approximately the top 10% of all tunnel fans tested by the BESS Laboratory.

Though fan performance is of course very important, it is important to keep in mind that there are other factors to consider when purchasing a fan, such as quality of construction, local dealer reputation, warranty and type of shutter (some types significantly reduce cleaning requirements). Though it can be difficult balancing all the factors when it comes to purchasing fans for a tunnel-ventilated house, in the long run you will find that it is time well spent

Michael Czarick
Extension Engineer
(706) 542-904`
mczarick@uga.edu
www.poultryventilation.com

Trade and brand names are used only for information. The Cooperative Extension Service, The University of Georgia College of Agriculture and Environmental Sciences does not guarantee nor warrant the standard of any product mentioned; neither does it imply approval of any products to the exclusion of others that may also be suitable

PUTTING KNOWLEDGE TO WORK

COLLEGE OF AGRICULTURAL AND ENVIRONMENTAL SCIENCES, COLLEGE OF FAMILY AND CONSUMER SCIENCES
WARNELL SCHOOL OF FOREST RESOURCES, COLLEGE OF VETERINARY SCIENCES

The University of Georgia and Fort Valley State University, the U.S. Department of Agriculture and counties of the state cooperating.
The Cooperative Extension Service offers educational programs, assistance and materials to all people without regard to race, color, national origin, age, sex or disability.
An equal opportunity/affirmative action organization committed to a diverse work force

Test #	Manufacturer	Model	Cone	Shutter	Cfm 0.05"	Cfm/watt 0.05"	Cfm 0.10"	Cfm/watt 0.10"	Air Flow Ratio
07204	Acme	BDR54J	Y	A	25,100	27.7	23,500	24.5	0.76
07206		BDR54J1	Y	A	27,400	25.4	25,900	22.7	0.81
02207		BDRV54J2-C2	Y	A	27,400	25.5	25,800	22.5	0.79
02210		BDRV54J-C2	Y	A	26,100	25.8	24,400	22.4	0.77
04274		DDPSV54J-C	Y	A	25,500	25.4	23,800	22.1	0.77
04278		DDPGV54J-C	Y	A	26,500	25.2	24,700	21.8	0.76
00245		BDR54J-C	Y	A	26,100	24.2	24,500	21.4	0.79
00207		DDPS48J-C	Y	A	20,400	23.9	19,100	21.3	0.77
02209		BDRV54J1-C2	Y	A	27,100	24.0	25,500	21.1	0.77
98142		DDPS48J-C	Y	A	21,400	23.2	20,300	20.9	0.83
10238	American Coolair	MNBCC54L	Y	A	26,900	25.6	25600	23	0.77
05236		MNBRDD52LE	Y	B	24,100	26.1	22,200	22.8	0.76
05233		MNBRDD52LE	Y	B	23,900	25.4	22,100	22.3	0.76
10236		MNBCCE54M	Y	A	29,800	23.7	28,100	21.5	0.81
10255		MNEFCE54M	Y	A	27,900	24.5	26,000	21.5	0.80
01216		MNBRC52L	Y	A	25,900	24.6	24,300	21.7	0.77
05235		MNBRDD52L	Y	B	25,100	24.2	23,500	21.4	0.78
07230		NBRID52L-SQ	Y	D	24,600	24.3	23,000	21.3	0.76
05234		MNBRDD52L	Y	B	24,900	23.8	23,100	20.9	0.77
14233		NEFXM54M	Y	B	28,600	24.1	26,900	21.5	0.79
15334	Cumberland	77-0173	Y	B	27,600	23.9	26,000	21.2	0.80
15336		77-0175	Y	B	28,200	23.7	26,500	21.0	0.81
09081	Chore-Time	52157-22	Y	B	27,700	25.3	25,800	22.0	0.78
12615		53464-21	Y	B	32,400	23.1	30,400	20.4	0.80
04336		49451-22	Y	B	21,200	24.8	19,700	21.6	0.76
04326		49515-22	Y	B	21,100	24.4	19,600	21.3	0.77
05192		49511-22	Y	B	26,400	23.9	24,600	21.2	0.76
05186		49519-22	Y	B	26,400	23.6	24,500	20.8	0.76
12620		53464-42 variable speed	Y	B	28,500	25.3	26,400	22.0	0.77
12614		53464-22	Y	B	28,900	26.1	27,100	23.0	0.78
13591		54659-22	Y	B	28,300	24.7	26,400	21.7	0.77
08250	Hired Hand	6603-7132	Y	B	26,700	24.3	25,200	21.8	0.80
04343		6603-0606	Y	A	27,000	23.3	25,300	20.8	0.78
15181	Munters/Aerotech	WM541F1CB	Y	B	29,100	25.0	27,200	22.3	0.77
15003		WM541G1CD	Y	B	28,700	23.4	27,000	21.1	0.80
06141		WF541T1CEJ	Y	A	27,800	25.0	26,000	22.3	0.77
07390		WF541V1CD	Y	B	27,800	24.6	25,900	21.7	0.77
06139		WF541T1CEP	Y	P	27,400	24.2	25,600	21.7	0.76
06115		WF541T1CJ	Y	A	27,300	23.6	25,400	20.9	0.77
09081p	Pro Terra Systems	A52157-22	Y	B	27,700	25.3	25,800	22.0	0.78
04336p		A49451-22	Y	B	21,200	24.8	19,700	21.6	0.76
04326p		A49515-22	Y	B	21,100	24.4	19,600	21.3	0.77
05192p		A49511-22	Y	B	26,400	23.9	24,600	21.2	0.76
05186p		A49519-22	Y	B	26,400	23.6	24,500	20.8	0.76
05203	Val-Co	HGS48G340NGA	Y	A	21,900	25.4	20,300	22.1	0.76
15664		954205-EXT	Y	A	28,100	23.9	26,600	21.8	0.80
15647		954200	Y	A	28,900	24.6	27,000	21.9	0.76
15646		954205	Y	A	28,500	24.3	27,100	22.3	0.79

Table 1. Alphabetical listing of best performing tunnel fans as tested by BESS Labs 2015
(A=Aluminum Shutter, G=Galvanized Shutter, P=Plastic Shutter, R=Roll Seal Shutter, B=Butterfly Shutter, D=Door)
New test for 2015